

PERFORMANCE OF DIRECT EVAPORATIVE COOLING SYSTEM UNDER EGYPTIAN CONDITIONS

El-Sayed G. Khater*

ABSTRACT

The main objective of this research is to optimize the parameters affecting the performance of the evaporative cooling system, to achieve that, a mathematical model of heat and mass balance of the evaporative cooling pads was developed to predict most important factors affecting the performance of the system. The model was able to predict the temperature, humidity ratio, wet bulb effectiveness, dew point effectiveness and temperature-humidity index of outlet air at different ambient air temperatures (25, 30, 35 and 40°C), different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹), ambient air humidities (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m). The results showed that the outlet temperature increases with increasing ambient temperature, inlet air velocity, ambient air humidities and lengths of pad. The results also showed that the wet bulb effectiveness decreases with increasing ambient temperature, inlet air velocity, ambient air humidities and it increases with increasing lengths of pad. On the other hand, the dew point effectiveness decreases with increasing ambient temperature, inlet air velocity, ambient air humidities and it increases with increasing lengths of pad. The humidity ratio decreases with increasing ambient temperature and inlet air velocity and it increases with increasing ambient air humidities and lengths of pad. The temperature-humidity index increases with increasing ambient temperature, inlet air velocity, ambient air humidities and lengths of pad. The predicted outlet temperatures were in a reasonable agreement with those measured, where, it ranged 17.027 to 29.978 °C theoretically while it was from 19.605 to 30.748 °C experimentally.

Keywords: evaporative cooling, temperature, humidity ratio, wet bulb effectiveness, dew point effectiveness, temperature-humidity index

*Lecturer, Agricultural Engineering Department – Faculty of Agriculture – Benha University, Egypt - E-mail address: alsayed.khater@fagr.bu.edu.eg

INTRODUCTION

U sing of water evaporation for decreasing air temperature is a well-known cooling technology and an environmental friendly application. Due to increase in the awareness of environmental problems resulting from greenhouse emissions, various applications of evaporative cooling have been extensively studied and used for industrial and residential sectors, such as, humidifier, cooling tower and evaporative cooler (**El-Dessouky, 1996; Cerci, 2003; Costellea and Finn, 2003; Sethi and Sharma, 2007; El-Refaie and Kaseb, 2009; Wu et al., 2009**).

Direct and indirect evaporative cooling systems are used to produce low temperature medium fluid (i.e., water, air, etc.). These systems usually require electricity (mostly) for the air transportation within the cooling process. Therefore, approximately two thirds of electrical power that mechanical vapor compression system consumes can be reduced (**Cerci, 2003; El-Refaie and Kaseb, 2009**), which thus reduces energy consumption and contributes to greenhouse gas reduction.

There are several researchers have been studied cooling energy, (**Maclaine-cross and Banks, 1981; Crum et al., 1987; El-Dessouky et al., 2004; Boxem et al., 2007; Zhao et al., 2008; Zhao et al., 2009; Riangvilaikul and Kumar, 2010; Zhan et al., 2011; Zhan et al., 2011; Caliskan et al., 2011**) studied that the cooling energy is a significant part of the energy needed in buildings. The need for cooling in buildings is increasing due to higher levels of targeted indoor environment in addition to the impacts of the global warming. Evaporative cooling is an efficient and sustainable method for cooling. Theoretically, the ultimate temperature for the evaporative cooling process is the ambient air wet bulb temperature, which is not easy to be reached practically. This is a main obstacle for wider utilization of evaporative cooling. Therefore processes that bring the air to temperatures lower than the wet-bulb temperature, without using a vapor compression cycles, need to be developed.

Riangvilaikul and Kumar (2010) developed a theoretical finite difference model of a dew point evaporative cooling system has been developed on heat and mass transfer processes. The performance of the

system, namely, outlet air condition and cooling effectiveness are predicted from the model with the known inlet parameters. The simulation results are compared with the experimental findings for various inlet air conditions (typically covering dry, moderate and humid climate) and for different intake air velocities (1.5 to 6 m s^{-1}). Good agreement and trend can be observed from both simulation and experimental results within 5 and 10% discrepancies of the outlet air temperature and effectiveness, respectively. Operating under different climate, the simulation results show that the dew point effectiveness varies significantly from 65 to 85% when the inlet air humidity changes from 6.9 to 26.4 g kg^{-1} at the constant inlet temperature (35°C). On the other hand, the wet bulb effectiveness is less sensitive ranging between 106 and 109% for the same inlet condition. Based on the analysis of influential parameters on the system performance, the system should be designed and operated at: intake air velocity below 2.5 m s^{-1} , channel gap less than 5 mm, channel height larger than 1 m and ratio of working air to intake around 35 – 60%, to obtain the wet bulb effectiveness greater than 100% for all typical inlet air conditions.

Reducing temperature during daylight is one of the main problems facing greenhouse management in warm climates such in Egypt during summer season in addition to the high cost of using refrigerated cooling system, therefore, the main objective of this work is to optimize the parameters affecting the performance of the evaporative cooling system, to achieve that a mathematical model of heat and mass balance of the evaporative cooling pads was developed to predict the most important factors affecting the performance of the system such as the temperature, humidity ratio, wet bulb effectiveness, dew point effectiveness and temperature-humidity index of outlet air at different ambient air temperatures, air flow rates, ambient air humidities and different lengths of pad.

MODEL DEVELOPMENT

The governing equations describing the temperature and humidity change of the dew point evaporative cooling are the simultaneous heat and mass transfer equations. Figure (1) represents the inputs and outputs of the heat and mass balance for evaporative cooling system.




Figure (1): The input and outputs of the heat and mass balance of evaporative cooling system.

The following assumptions for development of the present model are made:

- Temperature distribution of the water stream at any cross section is uniform.
- No heat and mass transfer between the system and the surrounding.
- The velocity and properties of all fluids are considered uniform within a differential control volume.
- The wet surface is entirely saturated with water evenly.
- Heat and mass transfer coefficients are constant along the pads.

Heat balance:

An energy balance of a differential control volume can be written as follows (**Incropera and DeWitt, 1990**):

$$\dot{m}_w C_{pm} dT = -h_w A (T - T_\infty) dt \tag{1}$$

Where:

- \dot{m}_w is the mass flow rate of intake air (kg s^{-1})
- C_{pm} is the specific heat moist air ($\text{kJ kg}^{-1} \text{°C}^{-1}$)
- T is the air temperature at any time, t (°C)
- T_∞ is the ambient temperature (°C)
- h_w is the heat transfer coefficient ($\text{W m}^{-2} \text{°C}^{-1}$)
- A is the cross section area (m^2)
- t is the time (s)

The specific heat of moist air is defined as (Riangvilaikul and Kumar, 2010):

$$C_{pm} = C_p + \omega \cdot C_v \quad (2)$$

Where:

C_p is the specific heat of dry air ($\text{kJ kg}^{-1} \text{ }^\circ\text{C}^{-1}$)

ω is the humidity ratio ($\text{kg water kg}^{-1}\text{dry air}$)

C_v is the specific heat of water vapor ($\text{kJ kg}^{-1} \text{ }^\circ\text{C}^{-1}$)

Heat transfer coefficient calculation:

To determine the heat transfer coefficient value (h_w), Nusselt number (Nu), Reynold's number (Re) and Prandtl number (Pr) will be calculated from the following equations:

The Nusselt number (Nu) is related to the heat transfer coefficient by:

$$N_u = \frac{h_w L_c}{k_{air}} \quad (3)$$

Where

L_c is the characteristic length of the surface (m)

k_{air} is the thermal conductivity of the air ($\text{kW m}^{-1} \text{ }^\circ\text{C}^{-1}$)

$$k_{air} = (1.52E - 11xT_\infty^3 - 4.86E - 08xT_\infty^2 + 1.02E - 04xT_\infty - 3.93E - 04)/1000 \quad (4)$$

The Nusselt number (Nu) in a rigid cellulose paper evaporative media (Dowdy and Karabash, 1987):

$$Nu = 0.1 \left(\frac{L_c}{L} \right)^{0.12} Re^{0.8} Pr^{1/3} \quad (5)$$

Where:

L is the pad thickness (m)

The Reynold's number, Re, can be calculated as follows:

$$Re = \frac{V_{air} \cdot L_c}{\nu} \quad (6)$$

Where

V_{air} is the velocity of the air (m s^{-1})

ν is the kinematic viscosity of the fluid ($\text{m}^2 \text{ s}^{-1}$).

The Prandtl number, Pr, can be calculated as follows:

$$Pr = \frac{\nu}{\alpha} \quad (7)$$

Where

α is the thermal diffusivity of the fluid ($\text{m}^2 \text{s}^{-1}$)

Mass balance:

Mass transfer takes place only at wetted surface under the driving force of vapor partial pressure difference. The mass exchange is balanced and written as (Naphon, 2005):

$$\dot{m}_w d\omega = h_m A (\omega_{\text{sat},w} - \omega) dV \quad (8)$$

Where:

h_m is the mass transfer coefficient ($\text{kg m}^{-2} \text{s}^{-1}$)

$\omega_{\text{sat},w}$ is the saturated humidity ratio at the water temperature (kg water kg^{-1} dry air)

V is the volume of the pad (m^3)

These governing equations demonstrate the profiles of the air temperature and humidity along the wet channel length which depend difference, respectively.

For air–water vapor mixtures in the wet passage, the relation of heat and mass transfer coefficients with Lewis number can be expressed as (Cengel, 2006 and Necati, 1985):

$$\frac{h_w}{h_m} = \rho C_{pm} L_e^{2/3} \quad (9)$$

Where:

L_e is the Lewis number (dimensionless)

The wet bulb effectiveness is defined as the ratio of the difference between intake and outlet air temperature to the difference between intake air temperature and its wet bulb temperature. The wet bulb effectiveness is defined as (Heidarinejad *et al.*, 2010):

$$\varepsilon_{wb} = \frac{(T_{s,in} - T_{s,out})}{(T_{s,in} - T_{wb,in})} \quad (10)$$

Where:

ε_{wb} is the wet bulb effectiveness

Since the dew point evaporative cooling system can sensibly cool the outlet air temperature below the ambient wet bulb temperature, the dew point effectiveness is used to indicate (a) its cooling performance

compared to its theoretical limitation, and (b) how close the outlet air temperature is to the dew point temperature of the intake air (ambient). The dew point effectiveness can be expressed as (Zhao *et al.* (2008):

$$\varepsilon_{dew} = \frac{(T_{s,in} - T_{s,out})}{(T_{s,in} - T_{dew,in})} \tag{11}$$

Where:

ε_{wb} is the dew point effectiveness

A temperature humidity index, THI, comprised of a linear combination of dry-bulb and wet-bulb temperature, has been used to estimate effect of heat stress (Fehr *et al.*, 1983 and DeShazer and Beck, 1988) which presented as follows:

$$THI = 0.6T_{db} + 0.4T_{wb} \tag{12}$$

Where:

THI is the temperature-humidity index, °C

T_{db} is the dry-bulb temperature, °C

T_{wb} is the wet-bulb temperature, °C

All computational procedures of the model were carried out using Excel spreadsheet. The computer program was devoted to heat and mass balance for predicting the temperature, humidity ratio, wet bulb effectiveness and dew point effectiveness of outlet air. Table (1) shows the parameters used in the model.

Table (1): The parameters used in the heat and mass balance.

Parameter	Units	Value	Source
Specific heat moist air, C_p	$\text{kJ kg}^{-1} \text{ }^\circ\text{C}^{-1}$	1.006	Dowdy and Karabash, 1987
Specific heat water vapor, C_v	$\text{kJ kg}^{-1} \text{ }^\circ\text{C}^{-1}$	0.503	Dowdy and Karabash, 1987
Kinematic viscosity, ν	$\text{m}^2 \text{ s}^{-1}$	1.8072×10^{-5}	Magee and Branshurg, 1995
Thermal diffusivity, α	$\text{m}^2 \text{ s}^{-1}$	1.28×10^{-6}	Magee and Branshurg, 1995
Air density, ρ	kg m^{-3}	1.28	Dowdy and Karabash, 1987
Lewis number, L_e	-	1	Heidarinejad <i>et al.</i> , 2010
Area, A	m^2	10	
Pad thickness, L	M	0.15	
Ambient temperature	$^\circ\text{C}$	25, 30, 35 and 40	
Humidity ratio	kg kg^{-1}	0.1, 0.2, 0.3 and 0.4	
Inlet air velocity	m s^{-1}	1.5, 3, 4.5 and 6	Riangvilaikul and Kumar, 2010
Length of pads	M	0.5, 1, 1.5 and 2	Santos <i>et al.</i> , 2013

MATERIALS AND METHODS

The experiment was carried out at Sekem Company, Belbeies, El-Sharkia Governorate, Egypt.

Figure (2) illustrates the experimental setup. It shows the evaporative cooling system which consists of two extracting fans (single speed, belt driven, 138 cm diameter, 34000 m³ h⁻¹ discharge and 2 hp power, Germany) were located on the leeward side of greenhouse (eastern direction). A fifteen cross-fluted cellulose pad plates were vertically placed in the opposite wall of the extracting fans (western direction) in the greenhouse. Each cellulose pad plate having a gross dimensions of 200 cm high, 60 cm wide and 10 cm thickness. A polyvinyl chloride pipe (PVC) 25.4 mm diameter and 9.0 m long was fixed on the middle above the cooling pads. Holes were drilled in a line about 5 cm apart along the top side of PVC pipe and the end of this pipe was capped. A baffle was placed above the water pipe to prevent any leaking of water from the cooling system. Sump (gutter) was situated underneath the cooling pads to collect the water and return it into the water tank (1000 liters capacity) from which it can be recycled to the cooling pads by a submersible water pump.




Figure (2): Evaporative cooling system components.

Temperature and relative humidity were recorded before and after the cooling pad using a HOBO Data Logger (Model HOBO U12 Temp/RH/Light – Range -20 to 70 °C and 5 to 95% RH, USA) every ten minutes.

RESULTS AND DISCUSSIONS

1- Model Experimentation:

- Outlet temperature at different ambient temperatures and inlet air velocities:

The outlet temperature at different ambient temperatures (25, 30, 35 and 40°C) and different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹) are shown in figure (3). The results indicate that the outlet temperature increases with increasing ambient temperature and inlet air velocity. It also indicate that when the ambient temperature increased from 25 to 40°C, the out temperature increased from 21.06 to 33.01°C at 1.5 m s⁻¹ air velocity, while it increased from 22.90 to 36.12°C at 6.0 m s⁻¹ air velocity. It decreased from 25 to 21.06°C (15.77%) and 40 to 33.01°C (17.48%) at 25 and 40°C ambient temperature, respectively at 1.5 m s⁻¹ air velocity, while it decreased from 25 to 22.90°C (8.40%) and 40 to 36.12°C (9.75%) at 25 and 40°C ambient temperature, respectively at 6.0 m s⁻¹ air velocity. The lowest value of outlet temperature was 21.06°C at the ambient temperature 25°C with 1.5 m s⁻¹ inlet air velocity and the highest value of outlet temperature was 36.12°C at the ambient temperature 40°C with 6.0 m s⁻¹ inlet air velocity. It is concluded that the outlet air temperature is decreased when the intake air velocity is reduced. For the same inlet air velocity, the higher inlet humidity provides significantly larger increase of outlet air temperature (**Riangvilaikul and Kumar, 2010**). The relevant results show that the system can provide the comfort condition when the inlet air velocity, temperature and humidity are maintained below 6m s⁻¹, 34°C and 11.2 g kg⁻¹, respectively (**Camargo and Ebinuma, 2002; Naphon, 2005**).




Figure (3): The outlet temperature at different ambient temperatures and inlet air velocities for the direct evaporative cooling system.

- **Outlet temperature at different ambient temperatures and humidity ratios:**

The outlet temperature at different ambient temperatures (25, 30, 35 and 40°C) and different humidity ratios (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) are shown in figure (4). The results indicate that the outlet temperature increases with increasing ambient temperature and humidity ratio for inlet air. It also indicate that when the ambient temperature increased from 25 to 40°C, the out temperature increased from 21.21 to 33.49°C at 0.01 kg kg⁻¹ humidity ratio, while it increased from 22.99 to 36.09°C at 0.04 kg kg⁻¹ humidity ratio. It decreased from 25 to 21.21°C (15.16%) and 40 to 33.49°C (16.28%) at 25 and 40°C ambient temperature, respectively at 0.01 kg kg⁻¹ humidity ratio, while it decreased from 25 to 22.99°C (8.04%) and 40 to 36.09°C (8.78%) at 25 and 40°C ambient temperature, respectively at 0.04 kg kg⁻¹ humidity ratio. The lowest value of outlet temperature was 21.21°C at the ambient temperature 25°C with 0.01 kg kg⁻¹ humidity ratio and the highest value of outlet temperature was 36.09°C at the ambient temperature 40°C with 0.04 kg kg⁻¹ humidity ratio. These results agreed with those obtained by **Camargo and Ebinuma (2002)** and **Riangvilaikul and Kumar (2010)**.




Figure (4): The outlet temperature at different ambient temperatures and humidity ratios.

- **Outlet temperature at different ambient temperatures and lengths of pad:**

The outlet temperature at different ambient temperatures (25, 30, 35 and 40°C) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m) are shown in

figure (5). The results indicate that the outlet temperature increases with increasing ambient temperature and length of pad. It also indicate that when the ambient temperature increased from 25 to 40°C, the out temperature increased from 21.09 to 33.32°C at 0.5 m length of pad, while it increased from 23.02 to 36.17°C at 2.0 m length of pad. It decreased from 25 to 21.09°C (15.64%) and 40 to 33.32°C (16.70%) at 25 and 40°C ambient temperature, respectively at 0.5 m length of pad, while it decreased from 25 to 23.02°C (7.92%) and 40 to 36.17°C (9.78%) at 25 and 40°C ambient temperature, respectively at 2.0 m length of pad. The lowest value of outlet temperature was 21.09°C at the ambient temperature 25°C with 0.5 m length of pad and the highest value of outlet temperature was 36.17°C at the ambient temperature 40°C with 2.0 m length of pad. These results agreed with those obtained by Santos *et al.* (2013).




Figure (5): The outlet temperature at different ambient temperatures and lengths of pad.

- **Wet bulb effectiveness at different ambient temperatures and inlet air velocities:**

The wet bulb effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹) are shown in figure (6). The results indicate that the wet bulb effectiveness increases with increasing ambient temperature and decreasing inlet air velocity. It also indicate that when the ambient temperature increased

from 25 to 40°C, the wet bulb effectiveness increased from 0.963 to 1.163 (17.20%) at 1.5 m s⁻¹ air velocity, while it increased from 0.878 to 0.997 (11.94%) at 6.0 m s⁻¹ air velocity. The lowest value of wet bulb effectiveness was 0.878 at the ambient temperature 25°C with 6.0 m s⁻¹ inlet air velocity and the highest value of wet bulb effectiveness was 1.163 at the ambient temperature 40°C with 1.5 m s⁻¹ inlet air velocity. The performance of the cooler under different inlet velocities. The cooling effectiveness of the cooler with installed ribs is effectively increased compared to the plain channel. When the inlet velocity is more than 1.5 m s⁻¹, the wet bulb effectiveness would increase by 10 - 20% for the cooler (Cui *et al.*, 2014).




Figure (6): The wet bulb effectiveness at different ambient temperatures and inlet air velocities.

- **Wet bulb effectiveness at different ambient temperatures and humidity ratios:**

The wet bulb effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different humidity ratios (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) are shown in figure (7). The results indicate that the wet bulb effectiveness increases with increasing ambient temperature and decreasing humidity ratio. It also indicate that when the ambient temperature increased from 25 to 40°C, the wet bulb effectiveness increased from 0.985 to 1.172 (15.96%) at 0.01 kg kg⁻¹ humidity ratio, while it increased from 0.894 to 1.001 (10.69%) at 0.04 kg kg⁻¹ humidity ratio. The lowest value of wet bulb effectiveness was 0.894 at the ambient temperature 25°C with 0.04 kg kg⁻¹ humidity ratio and the

highest value of wet bulb effectiveness was 1.172 at the ambient temperature 40°C with 0.01 kg kg⁻¹ humidity ratio. These results agreed with those obtained by **Riangvilaikul and Kumar (2010)** and **Cui *et al.* (2014)**.




Figure (7): The wet bulb effectiveness at different ambient temperatures and humidity ratios.

- **Wet bulb effectiveness at different ambient temperatures and lengths of pad:**

The wet bulb effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m) are shown in figure (8). The results indicate that the wet bulb effectiveness increases with increasing ambient temperature and decreasing lengths of pad. It also indicate that when the ambient temperature increased from 25 to 40°C, the wet bulb effectiveness increased from 0.873 to 0.999 (12.61%) at 0.5 m length of pad, while it increased from 0.953 to 1.159 (17.77%) at 2.0 m length of pad. The lowest value of wet bulb effectiveness was 0.873 at the ambient temperature 25°C with 0.5 m length of pad and the highest value of wet bulb effectiveness was 1.159 at the ambient temperature 40°C with 2.0 m length of pad. These results agreed with those obtained by **Santos *et al.* (2013)**.




Figure (8): The wet bulb effectiveness at different ambient temperatures and lengths of pad.

- **Dew point effectiveness at different ambient temperatures and inlet air velocities:**

The dew point effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹) are shown in figure (9). The results indicate that the dew point effectiveness increases with increasing ambient temperature and decreasing inlet air velocity. It also indicate that when the ambient temperature increased from 25 to 40°C, the dew point effectiveness increased from 0.599 to 0.792 (24.37%) at 1.5 m s⁻¹ air velocity, while it increased from 0.535 to 0.688 (22.24%) at 6.0 m s⁻¹ air velocity. The lowest value of dew point effectiveness was 0.535 at the ambient temperature 25°C with 6.0 m s⁻¹ inlet air velocity and the highest value of dew point effectiveness was 0.792 at the ambient temperature 40°C with 1.5 m s⁻¹ inlet air velocity.




Figure (9): The dew point effectiveness at different ambient temperatures and inlet air velocities.

- **Dew point effectiveness at different ambient temperatures and humidity ratios:**

The dew point effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different humidity ratios (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) are shown in figure (10). The results indicate that the dew point effectiveness increases with increasing ambient temperature and decreasing humidity ratio. It also indicate that when the ambient temperature increased from 25 to 40°C, the dew point effectiveness increased from 0.589 to 0.801 (26.47%) at 0.01 kg kg⁻¹ humidity ratio, while it increased from 0.528 to 0.702 (24.79%) at 0.04 kg kg⁻¹ humidity ratio. The lowest value of dew point effectiveness was 0.528 at the ambient temperature 25°C with 0.04 kg kg⁻¹ humidity ratio and the highest value of dew point effectiveness was 0.801 at the ambient temperature 40°C with 0.01 kg kg⁻¹ humidity ratio. The evaporative cooling is able to cool air to the temperature below and the dew point effectiveness spans 0.81 – 0.93, when the inlet air temperature was varied from 25 to 40°C and the humidity ratio was varied from 8 to 20 g kg⁻¹. The inlet air velocity was kept as 1 m s⁻¹. Other parameters were under pre-set conditions (Cui *et al.*, 2014).




Figure (10): The dew point effectiveness at different ambient temperatures and humidity ratios.

- **Dew point effectiveness at different ambient temperatures and lengths of pad:**

The dew point effectiveness at different ambient temperatures (25, 30, 35 and 40°C) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m) are shown in figure (11). The results indicate that the dew point effectiveness increases with increasing ambient temperature and decreasing length of

pad. It also indicate that when the ambient temperature increased from 25 to 40°C, the dew point effectiveness increased from 0.533 to 0.704 (24.29%) at 0.5 m length of pad, while it increased from 0.586 to 0.800 (26.75%) at 2.0 m length of pad. The lowest value of dew point effectiveness was 0.533 at the ambient temperature 25°C with 0.5 m length of pad and the highest value of dew point effectiveness was 0.80 at the ambient temperature 40°C with 2.0 m length of pad.




Figure (11): The dew point effectiveness at different ambient temperatures and lengths of pad.

- **Humidity ratio at different ambient temperatures and inlet air velocities:**

The humidity ratio at different ambient temperatures (25, 30, 35 and 40°C) and different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹) are shown in figure (12). The results indicate that the humidity ratio increases with increasing ambient temperature and inlet air velocity. It also indicate that when the ambient temperature increased from 25 to 40°C, the humidity ratio increased from 0.027 to 0.038 kg kg⁻¹ (28.95%) at 1.5 m s⁻¹ air velocity, while it increased from 0.024 to 0.031 kg kg⁻¹ (22.58%) at 6.0 m s⁻¹ air velocity. The lowest value of humidity ratio was 0.027 kg kg⁻¹ at the ambient temperature 25°C with 1.5 m s⁻¹ inlet air velocity and the highest value of humidity ratio was 0.038 kg kg⁻¹ at the ambient temperature 40°C with 6.0 m s⁻¹ inlet air velocity. These results agreed with those obtained by **Zhan *et al.* (2011)** whose found the humidity ratio increased with increasing the inlet air temperature.




Figure (12): The humidity ratio effectiveness at different ambient temperatures and inlet air velocities.

- **Humidity ratio at different ambient temperatures and humidity ratios:**

The humidity ratio at different ambient temperatures (25, 30, 35 and 40°C) and different humidity ratios (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) are shown in figure (13).




Figure (13): The humidity ratio effectiveness at different ambient temperatures and humidity ratios.

The results indicate that the humidity ratio increases with increasing ambient temperature and humidity ratio for inlet air. It also indicate that when the ambient temperature increased from 25 to 40°C, the humidity ratio increased from 0.014 to 0.019 kg kg⁻¹ (26.32%) at 0.01 kg kg⁻¹ humidity ratio, while it increased from 0.048 to 0.055 kg kg⁻¹ (12.73%) at 0.04 kg kg⁻¹ humidity ratio. The lowest value of humidity ratio was 0.014 kg kg⁻¹ at the ambient temperature 25°C with 0.01 kg kg⁻¹ humidity ratio and the highest value of humidity ratio was 0.055 kg kg⁻¹ at the ambient temperature 40°C with 0.04 kg kg⁻¹ humidity ratio.

- **Humidity ratio at different ambient temperatures and lengths of pad:**

The humidity ratio at different ambient temperatures (25, 30, 35 and 40°C) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m) are shown in figure (14). The results indicate that the humidity ratio increases with increasing ambient temperature and length of pad. It also indicate that when the ambient temperature increased from 25 to 40°C, the humidity ratio increased from 0.023 to 0.031 kg kg⁻¹ (25.81%) at 0.5 m length of pad, while it increased from 0.028 to 0.038 kg kg⁻¹ (26.32%) at 2.0 m length of pad. The lowest value of humidity ratio was 0.023 kg kg⁻¹ at the ambient temperature 25°C with 0.5 m length of pad and the highest value of humidity ratio was 0.038 kg kg⁻¹ at the ambient temperature 40°C with 2.0 m length of pad.




Figure (14): The humidity ratio effectiveness at different ambient temperatures and lengths of pad.

- **Temperature-humidity index (THI) at different ambient temperatures and inlet air velocities:**

The temperature-humidity index at different ambient temperatures (25, 30, 35 and 40°C) and different inlet air velocities (1.5, 3, 4.5 and 6 m s⁻¹) are shown in figure (15). The results indicate that the temperature-humidity index increases with increasing ambient temperature and inlet air velocity. It also indicate that when the ambient temperature increased from 25 to 40°C, the temperature-humidity index increased from 20.23 to 31.47°C (35.17%) at 1.5 m s⁻¹ air velocity, while it increased from 21.84 to 35.68°C (38.79%) at 6.0 m s⁻¹ air velocity. The lowest value of temperature-humidity index was 20.23°C at the ambient temperature 25°C with 1.5 m s⁻¹ inlet air velocity and the highest value of temperature-humidity index was 35.68°C at the ambient temperature 40°C with 6.0 m s⁻¹ inlet air velocity.




Figure (15): The temperature-humidity index effectiveness at different ambient temperatures and inlet air velocities.

- **Temperature-humidity index (THI) at different ambient temperatures and humidity ratios:**

The temperature-humidity index at different ambient temperatures (25, 30, 35 and 40°C) and different humidity ratios (0.01, 0.02, 0.03 and 0.04 kg kg⁻¹) are shown in figure (16). The results indicate that the temperature-humidity index increases with increasing ambient temperature and humidity ratio. It also indicate that when the ambient temperature increased from 25 to 40°C, the temperature-humidity index

increased from 20.27 to 31.70°C (36.06%) at 0.01 kg kg⁻¹ humidity ratio, while it increased from 22.01 to 35.51°C (38.02%) at 0.04 kg kg⁻¹ humidity ratio. The lowest value of temperature-humidity index was 20.27°C at the ambient temperature 25°C with 0.01 kg kg⁻¹ humidity ratio and the highest value of temperature-humidity index was 35.51°C at the ambient temperature 40°C with 0.04 kg kg⁻¹ humidity ratio.




Figure (16): The temperature-humidity index effectiveness at different ambient temperatures and humidity ratios.

- **Temperature-humidity index (THI) at different ambient temperatures and lengths of pad:**

The temperature-humidity index at different ambient temperatures (25, 30, 35 and 40°C) and different lengths of pad (0.5, 1.0, 1.5 and 2.0 m) are shown in figure (17). The results indicate that the temperature-humidity index increases with increasing ambient temperature and length of pad. It also indicate that when the ambient temperature increased from 25 to 40°C, the temperature-humidity index increased from 20.66 to 31.62°C (34.66%) at 0.5 m length of pad, while it increased from 21.99 to 35.72°C (38.44%) at 2.0 m length of pad. The lowest value of temperature-humidity index was 20.99°C at the ambient temperature 25°C with 0.5 m length of pad and the highest value of temperature-humidity index was 35.72°C at the ambient temperature 40°C with 2.0 m length of pad.




Figure (17): The temperature-humidity index effectiveness at different ambient temperatures and lengths of pad.

2- Model Validation:

Figure (18) shows the predicted and the measured outlet temperatures of evaporative cooling system. It could be seen that, the predicted outlet temperatures were in a reasonable agreement with those measured, where, it ranged 17.027 to 29.978 °C theoretically while it was from 19.605 to 30.748 °C experimentally.

Regression analysis was carried out to find a relationship between the predicted and measured outlet temperatures and the most suitable form is shown as follows (figure 19):

$$T_P = 0.757T_M + 5.8753 \quad R^2 = 0.86 \quad (13)$$

Where:

T_P is the predicted temperature, °C

T_M is the measured temperature, °C




Figure (18): The predicted and the measured outlet temperatures of evaporative cooling system.




Figure (19): The comparison between the predicted and the measured outlet temperatures of evaporative cooling system.

CONCLUSIONS

A mathematical model for the direct evaporative cooling system was developed successively according to heat balance to optimize the main factors affecting the performance of evaporative cooling system through studying of outlet temperature, humidity ratio, wet bulb effectiveness, dew point effectiveness and temperature-humidity index at different ambient temperatures, inlet air velocities, humidity ratios and lengths of pad. Also, carrying out an experiment to validate the model results through measuring: outlet temperature. The most important results obtained can be summarized as follows:

- The average outlet temperature increased from 22.07 to 34.72°C with increasing ambient temperature from 25 to 40°C, while it increased from 27.31 to 29.68°C with increasing inlet air velocity from 1.5 to 6.0 m s⁻¹. It increased from 27.39 to 29.72°C with increasing humidity ratio from 0.01 to 0.04 kg kg⁻¹, and from 27.35 to 29.85°C with increasing length of pad from 0.5 to 2.0 m.
- The average wet bulb effectiveness increased from 0.927 to 1.086 with increasing ambient temperature from 25 to 40°C. On the other hand, it decreased from 1.075 to 0.953 with increasing inlet air velocity from 1.5 to 6.0 m s⁻¹, while it decreased from 1.079 to 0.961

with increasing humidity ratio from 0.01 to 0.04 kg kg⁻¹. The wet bulb effectiveness increased from 0.951 to 1.074 with increasing length of pad from 0.5 to 2.0 m.

- The average dew point effectiveness increased from 0.561 to 0.747 with increasing ambient temperature from 25 to 40°C. On the other hand, it decreased from 0.695 to 0.613 with increasing inlet air velocity from 1.5 to 6.0 m s⁻¹, while it decreased from 0.690 to 0.615 with increasing humidity ratio from 0.01 to 0.04 kg kg⁻¹. The dew point effectiveness increased from 0.619 to 0.693 with increasing length of pad from 0.5 to 2.0 m.
- The average humidity ratio increased from 0.027 to 0.035 kg kg⁻¹ with increasing ambient temperature from 25 to 40°C, while it increased from 0.025 to 0.034 kg kg⁻¹ with increasing inlet air velocity from 1.5 to 6.0 m s⁻¹. It increased from 0.031 to 0.037 kg kg⁻¹ with increasing humidity ratio from 0.01 to 0.04 kg kg⁻¹ and from 0.026 to 0.034 kg kg⁻¹ with increasing length of pad from 0.5 to 2.0 m.
- The average temperature-humidity index increased from 21.15 to 33.56°C with increasing ambient temperature from 25 to 40°C, while it increased from 25.57 to 28.29°C with increasing inlet air velocity from 1.5 to 6.0 m s⁻¹. It increased from 25.72 to 28.34°C with increasing humidity ratio from 0.01 to 0.04 kg kg⁻¹ and from 25.67 to 28.48°C with increasing length of pad from 0.5 to 2.0 m.
- The predicted outlet temperature was in a reasonable agreement with the measured ones with a coefficient of determination of 0.86, where. It ranged from 17.027 to 29.978 °C, while the measured outlet temperature ranged from 19.605 to 30.748 °C.

REFERENCES

- Boxem, G., S. Boink and W. Zeiler (2007).** Performance model for small scale indirect evaporative cooler. In: Proceedings of Clima 2007 WellBeing Indoors, REHVA world congress. Paper No. 1676, 10 – 14 June, 2007, Helsinki, Finland.
- Caliskan, H., A. Hepbasli, I. Dincer and V. Maisotsenko (2011).** Thermodynamic performance assessment of a novel air cooling cycle: Maisotsenko cycle. *Int. J. Refrig.*, 34: 980 – 990.

- Camargo, J. R. (2005).** An evaporative and desiccant cooling system for air conditioning in humid climates. *J. Braz. Soc. Mech. Sci. Eng.* XXVII (2005): 243 - 247.
- Camargo, J. R. and C. D. Ebinuma (2002).** A mathematical model for direct and indirect evaporative cooling air conditioning systems. In: *Proceedings of the ninth Brazilian congress of thermal engineering and sciences, CONEM.*
- Cengel, Y. A. (2006).** *Heat and Mass Transfer: A Practical Approach,* McGraw-Hill Companies, Inc., Singapore.
- Crum, D. R., J. W. Mitchell and W. A. Beckman (1987).** Indirect evaporative cooler performance. *ASHRAE Trans.* 93 (1):1261 – 1275.
- Cui, X., K. J. Chua, W. M. Yang, K. C. Ng, K. Thu and V. T. Nguyen (2014).** Studying the performance of an improved dew-point evaporative design for cooling application. *Applied Thermal Engineering*, 63: 624 – 633.
- DeShazer, J. A. and M. M. Beck (1988).** University of Nebraska report for northeast regional Poultry Project NE-127. Agriculture Research Division, University of Nebraska, Lincoln.
- Dowdy, J. A. and N. S. Karabash (1987).** Experimental determination of heat and mass transfer co-efficients in rigid impregnated cellulose evaporative media. *ASHRAE Trans.*, 93(2): 382 – 395.
- El-Dessouky, H., H. Ettouney, and A. Al-Zeefari (2004).** Performance analysis of two-stage evaporative coolers. *Chem. Eng. J.*, 102 (3): 255 – 266.
- El-Refaie, M. F. and S. Kaseb (2009).** Speculation in the feasibility of evaporative cooling. *Build. Environ.* 44: 826 - 838.
- Fehr, R. L., K. T. Priddy, S. G. McNeil and D. G. Overhults (1983).** Limiting swine stress with evaporative cooling in the Southeast. *Transaction of the ASAE*, 26(2): 542 - 545.
- Heidarinejad, G., M. F. Farahani and S. Delfani (2010).** Investigation of a hybrid system of nocturnal radiative cooling and direct evaporative cooling. *Build. Environ.* 45: 1521 - 1528.
- Hirst, E. (1973).** *Efficiency of Energy Use in the United States.* Oak Ridge National Laboratory, 179: 1299 - 1304.

- Hunn, B. D. and J. L. Peterson (1997).** Cost-effectiveness of indirect evaporative cooling for commercial buildings in Texas. *ASHRAE Trans.* 103: 434 - 447.
- Incropera, F. P. and D. P. DeWitt (1990).** Introduction to heat transfer. 2nd (Ed.), John Wiley and Sons, Inc. New York.
- Maclaine-cross I. L. and P. J. Banks (1981).** A general theory of wet surface heat exchangers and its application to regenerative evaporative cooling. *J. Heat Transfer*, 103 (3): 579 – 585.
- Magee, T. R. and T. Branshurg (1995).** Measurement of thermal diffusivity of potato, malt bread and wheat flour. *Journal of Food Engineering*, 25(2): 223 - 232.
- Naphon, P. (2005).** Study on the heat transfer characteristics of an evaporative cooling tower. *International Communications in Heat and Mass Transfer* 32: 1066 – 1074.
- Necati, O. M. (1985).** Heat Transfer, McGraw-Hill Companies, Inc., Singapore, 1985.
- Phillips, P. E. (2009).** Using direct evaporative cooling and chilled water cooling. American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc.
- Riangvilaikul, B. and S. Kumar (2010).** An experimental study of a novel dew point evaporative cooling system. *Energy Build*, 42: 637 – 644.
- Riangvilaikul, B. and S. Kumar (2010).** Numerical study of a novel dew point evaporative cooling system. *Energy and Buildings*, 42: 2241 – 2250.
- Santos, J. C., G. D. T. Barros, J. M. Gurgel and F. Marcondes (2013).** Energy and exergy analysis applied to the evaporative cooling process in air washers. *International Journal of Refrigeration*. 36 (3): 1154 – 1161.
- Watt, J. R. and W. K. Brown (1997).** Evaporative Air Conditioning Handbook, 3rd Ed., The Fairmont Press, Inc., Lilburn, GA.
- Zhan, C., X. Zhao, S. Smith and S.B. Riffat (2011).** Numerical study of a M-cycle cross-flow heat exchanger for indirect evaporative cooling. *Build Environ.* 46: 657 – 668.

- Zhan, C., Z. Duan, X. Zhao, S. Smith, H. Jin and S. Riffat (2011).** Comparative study of the performance of the M-cycle counter-flow and cross-flow heat exchangers for indirect evaporative cooling paving the path toward sustainable cooling of buildings. *Energy*, 36: 6790 - 6805.
- Zhao, X., J. M. Li and S. B. Riffat (2008).** Numerical study of a novel counter-flow heat and mass exchanger for dew point evaporative cooling. *Appl. Therm. Eng.*, 28 (14 – 15):1942 – 1951.
- Zhao, X., Z. Duan, C. Zhan and S. B. Riffat (2009).** Dynamic performance of a novel dew point air conditioning for the UK buildings. *Int. J. Low Carbon Technol.*, 4 (1): 27 – 35.

الملخص العربي

معدل أداء نظام التبريد التبخيري المباشر تحت الظروف المصرية

السيد جمعه خاطر*

يهدف هذا البحث إلى دراسة العوامل التي تؤثر على معدل أداء نظام التبريد التبخيري للوصول إلى المعدلات المثلى له، ويتم ذلك من خلال تطوير نموذج رياضي لالتزان الحراري والكتلي للنظام للتنبؤ بالعوامل الهامة المؤثرة على معدل أداء النظام مثل درجة الحرارة والمحتوى الرطوبي وفاعلية درجة الحرارة الرطبة ونقطة الندى وكذلك دليل الحرارة والرطوبة وذلك تحت ظروف مختلفة وهي درجة حرارة الهواء المحيط بالنظام والمحتوى الرطوبي له وسرعة دخول الهواء وارتفاع الوسادة.

وقد اظهرت نتائج النموذج زيادة درجة حرارة الهواء الخارج من النظام بزيادة كلا من درجة حرارة الهواء الداخل والمحتوى الرطوبي له وسرعة دخوله وارتفاع الوسادة. انخفضت فاعلية درجات الحرارة الرطبة بزيادة كلا من درجة حرارة الهواء الداخل وسرعته ومحتوى الرطوبي بينما زادت بزيادة طول الوسادة. انخفضت فاعلية درجة حرارة نقطة الندى بزيادة كلا من درجة حرارة الهواء الداخل وسرعته ومحتوى الرطوبي بينما زادت بزيادة طول الوسادة. انخفض المحتوى الرطوبي للهواء الخارج من النظام بزيادة درجة حرارة الهواء الداخل وزيادة سرعته بينما زاد المحتوى الرطوبي للهواء الخارج من النظام بزيادة المحتوى الرطوبي للهواء الداخل وزيادة طول الوسادة. زاد دليل الحرارة والرطوبة للهواء الخارج من النظام بزيادة كلا من درجة حرارة الهواء الداخل والمحتوى الرطوبي له وسرعة دخوله وارتفاع الوسادة. واتفقت نتائج درجة الحرارة المتنبأ بها مع نتائج درجات الحرارة المقاسة حيث تراوحت درجة الحرارة النظرية ما بين 17,027 – 29,978 °م بينما تراوحت درجة الحرارة المقاسة ما بين 19,605 – 30,748 °م عند نفس الظروف.

*مدرس الهندسة الزراعية – كلية الزراعة بمشتهر – جامعة بنها